

Ln. M. SAPPANY PILLAI,

B.E., M.I.E., F.I.V., MICA

and Associates

CHARTERED ENGINEER - M/113880/9

GOVT. APPROVED VALUER - C1/170/1990

APPROVED BY AXIS BANK,

BANK OF BARODA, BANK OF CEYLON,

BANK OF MAHARASHTRA, CANARA BANK,

CORPORATION BANK, CATHOLIC SYRIAN BANK,

CITY UNION BANK, COSMOS BANK, DENA BANK,

ESSELS FINANCE LTD., FEDERAL BANK,

HUDCO, IOB, IOC, IFCI, JAMMU & KASHMIR,


KOTAK MAHINDRA BANK, NATIONAL INSURANCE CO.,

KARNATAKA BANK, OBC, PUNJAB SINDH BANK, REPCO BANK,

SOUTH INDIAN BANK, TMB, UNITED BANK OF INDIA,

UNION BANK OF INDIA, UNITED INDIA INSURANCE CO.,

VIJAYA BANK, YES BANK, OTHER BANKS INCOME TAX DEPT. ETC.



SERVICE ACROSS
THE NATION

Off : 044-28525589

044-28522447

Mobile : 98410 37806

72990 37807

E-mail : sappanypillai@yahoo.com (Per)

sappanypillai@gmail.com (Off)

GST No. : 33AAVPS952BG1Z0

Pan No. : AAVPS9528G

- ★ Registered Valuer under IBBI
Regd. No. IBBI RV/05/2018/10427
- ★ Registered as Valuer under Sec.34AB /
Sec. 34AE of the Wealth Tax Act.
- ★ Competent Person to issue
Stability Assessment by Chennai,
Kancheepuram & Tiruvallur


REGISTERED ENGINEER

Ref: Val/Admin/d/Stability/Sri Chaitanya School /Pre/July -04/19

03-07-2019

STATEMENT ACCOMPANYING FORM 'A'

1. Name or Door Number of building : M/s. Sri Chaitanya Techno School,
2. Location (Street No. Ward No) : Door No.11, Royal Avenue,
Moolakadai, Chennai-600 060
- Name of place, i.e. Corporation : S.No.1065/1A1, T.S.No.11,
Municipality, panchyat/ Panchayat, Block No.58, Madhavaram Village,
Union/Township/Cantonment Madhavaram Taluk, Chennai District
3. Year of construction : 2019
4. Approximate cost of construction
as per current rates : Rs.6 Crores
5. Purpose for which the building is
being used or proposed to be used. : Educational Purpose
6. Purpose for which the building
has either to been used. : School
7. Details of construction of the
building (particulars) of the :
foundation soil, specification of
the various parts under


Ln. M. SAPPANY PILLAI, B.E., F.I.V.,
Regd. Valuer-C-1/170-1990
Chartered Engineer-M/113880/9
Licenced Surveyor No.1822/2017/18
New No: 299/146, Peters Road,
Thousand Lights, Chennai - 600 086.
Phone: 28525589 / 28522447

- a) Foundation : Column Foundation
 b) Basement : Plinth Beam with Brick Masonry Wall
 c) Superstructure : Rcc Beam and Column & Brick Masonry Structure
 d) Floor and roof : R.C.C Roof and Tile Flooring
 e) Floor and roof area to be given :

Ground Floor : 955.39 sqm
 First Floor : 926.81 sqm
 Second Floor : 926.81 sqm
Total : 2809.01 sqm


8. Period for which license is required : Three years From : 03-07-2019
 To : 02-07-2022

9. Number of Persons to be accommodated : About 400 Pupils

Certified that no additions or alteration has been made to the existing building or portion of a building for which this application has been made. I under take to obtain a fresh license in case any addition or alteration is made to the existing building or portion of building. I also under take to obtain a fresh license if the purpose of the building for which the license was granted for the use of the building of a portion of the building originally is changed or shifted subsequently.

Dated: 03-07-2019

Signature of the Owner of the building


 Signature of Engineer



FORM- B

Certified that the building of M/s. Sri Chaitanya Techno School, declare that the Building is Situated at, Door No.11, Royal Avenue, Moolakadai, Chennai-600 060, was inspected on 03-07-2019 mentioned in the statement below. I have satisfied myself that the building structurally sound to be used as a Public Building for the purposes noted in the statement. The structural soundness of the building has been verified taking into account the loading as per the latest Indian Standards IS:895. The scope of this Stability Certificate is limited only to the structural soundness of the subject building (and no other structure in the premises) as per IS:456-1978: this does not include the eventualities caused by natural calamities like cyclone, earthquakes, high gales & storm, lightening ,floods, fire etc.,

Dated : 03-07-2019



Signature of the Engineer



FORM - C

Form of certificate of structural soundness under sub-section (4) of section 4 of the Tamil Nadu Public Building (Licensing) Act 1965 (Tamil Nadu Act 1 of 1965) Referred to in Rule 4 of the Tamil Nadu Public (Licensing) Rules 1966.

I certify that I have inspected the building mentioned in the statement and furnished below its salient technical features;

1. Foundation:

- | | | |
|--|---|-----------------|
| a) Depth below ground level | : | 3 mts |
| b) Nature of soil set out in the foundation level | : | Silty Clay Soil |
| c) Pressure at foundation | : | 18 M.Tons/sq.m. |
| d) Probable safe bearing capacity of the statement with at foundation. | : | 20 M.Tons/sq.m. |

2. Superstructure

- | | | |
|---|---|---|
| (i) Maximum stress in the most critical section of the masonry and concrete | : | Masonry : Within the limits
RCC Column : Within the limits |
| (ii) Nature of masonry and concrete and its safe permissible stress | : | Masonry : 5.00 kg per Sq cm
Concrete : 50.0 kg per Sq cm |

The structural soundness of the building has been verified by me with reference to ISI loading standards 895 (latest version) and other relevant Indian Standard Code for practices and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A license may granted for the period **From 03-07-2019 To 02-07-2022**

Dated : 03-07-2019

Signature of the Engineer.



