



## Bruhat Bengaluru Mahanagara Palike

Bommanahalli Zone  
BBMP, Bangalore-68

Date: 20/01/2019

### BUILDING SOUNDNESS CERTIFICATE

WITH RESPECT TO THE BUILDING SRI CHAITANYA TECHNO SCHOOL COMPLETED AT #75, 1A,  
BANNERGHATTA MAIN ROAD, HULIMAVU GATE BANGALORE 560076.

I have personally inspected the building and examined the soil and foundation by exposing foundation, and have examined the load bearing members of existing ground floor/first/second/Third floor and having calculated the loads coming on foundation/load bearing members. The details of soil and the foundation are as follows:

- |  |                             |
|--|-----------------------------|
| 1. Nature of Soil  | - Gravel and Sandy          |
| 2. Total Area  | - 64910 sqft                |
| 3. Safe bearing capacity of the solid  | - 1.5T/M2                   |
| 4. Depth and Width of the foundation   | - Depth 1.8m. & Width 1.2m. |
| 5. Load coming on foundation and the superstructure from the existing and proposed structure | - 1T/Sqm.                   |
| 6. Structure   | - RCC Column and beams      |

I certify that the existing building is structurally sound for the purpose it is built for and the substructure will take the load of the existing and proposed completed structures.

Ringaradi,  
Sunsham Di-5

**BLACKBOX DESIGN STUDIO**  
# 170/2, First Floor, Next to Bani Bani - 1st,  
"Shankarappa Nagar, Kalyan" - Post 42400,  
BANGALORE - 560 085.