

Memo No:- 460

Date:- 19/04/2023

Subject : Bacteriological Examination Report of Water Sample

Sample ID:	KTL/00194/4/2023	Sample Details	Date & Time
Sample Classification:	Private	Collected By	,9728896306
Sender:	Sunshine public school jind kaithal20020	Collection Date	17/04/2023 at 14:04
Location :-	, Tubel at sunshine public school kaithal	Received at lab	17/04/2023 at 14:10
Latitude :-	76.399398	Tested at Lab	19/04/2023
Longitude :-	29.754393		

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	0	Shall not be detectable in any 100 ml sample	IS 15185:2016/ APHA 9221C; 2017

Remarks :-

- * The Results Given above are related to the sample as received and tested in KAITHAL lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.

Water Sample has been found **"CONFORMING"** to Limits set in BIS10500:2012 for the tested parameters.
Based on the tested parameters,the water sample is found **"POTABLE"**



SUBHASH CHANDER, CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING LABORATORY, KAITHAL
email:-chemist.kaithal@phedharyana.gov.in

-----End of Report-----