

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 27.12.2023

It is certified that an inspection team headed by **Mr.E.Ramesh Sanitary Inspector** from **Tambaram City Municipal Corporation** inspected the **Sri Chaitanya Techno School, Plot No.110, GST Road, Pallavaram, Chennai – 600043**. On 27.12.2023 and found that the School has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

The above is valid for a period of 27.12.2023 to 26.12.2024



Signature with Seal : 27/12/23

9
27/12

Name : Dr. Arul Anand

Designation : City Health Officer

Name & Address of the

Office / Department :

Tambaram City Municipal Corporation

To

The Principal

Sri Chaitanya Techno School

Plot No.110, GST Road,

Adjacent to Pallavaram flyover,

Pallavaram, Chennai – 600044.

Priyamai

Principal

Sri Chaitanya Techno School

No. 110, G.S.T. Road,

Pallavaram, Chennai – 600043

For SREE MURAGAN EDUCATIONAL

MANAGER.

GSTIN: 33AAALT0834FBZ1

GSTIN: 33AAALT0834FBZ1

CUS-FRM-02



TWAD BOARD

STATE LEVEL WATER TESTING LABORATORY

(NABL Accredited)

Chepauk, Chennai-600 005. Ph.: 044-28412098

Invoice No.

2997

Date: 08/01/24

To: Sri Chaitanya Techno School
No. 110, G.S.T. Road, Pallavaram,
Chennai - 600 043.

Your Ref. No. -

Date: 08/01/24

Our Ref. No. SB33/CWA/TWD/HO/CH-5

Date: 08/01/24

No	DESCRIPTION	No. of Samples	Rate	Total Rs.	Ps.
I.	Towards analytical charges for: Water sample: a) Physico Chemical Examination (Full/Partial) b) Bacteriological Examination (Full/Partial) c) Construction.	1	1000	1000	
II.	Waste Water/ Sewage/ Effluent a) Physico Chemical Examination (Full/Partial) b) Bacteriological Examination (Full/Partial)			90	
III.	Treatment Chemicals a) Alum b) Bleaching Powder (Domestic/Commercial)			90	
				1180	
	E. & O.E.				

(Rupees One Thousand One Hundred and Eighty Only)

Payment should be made in the form of Demand Draft
drawn in favour of The Deputy Chief Engineer (CM)
TWAD Board, Chennai-600 005.

DD-NO: 524233

Bank: SBI, Tambaram

Dt: 08/01/24

g. Om
8/1/24
Chief Water Analyst/ Quality Manager
TWAD Board, Chennai- 600 005.

8/1/24

Priyamai

Principal

Sri Chaitanya Techno School
No. 110, G.S.T. Road,
Pallavaram, Chennai - 600 043.

For SREE MURAGAN EDUCATIONAL TRUST

MANAGER

**Test Report**

Sample Receipt No/Date :	2440/Dt.08.01.2024		
Invoice Details :	2997/Dt.08.01.2024/ Amt-Rs.1180/-		
Customer Name and Address	Sri Chaitanya Techno School, No.110, GST Road, Pallavaram, Chennai-600043		
Test Commenced on :	08.01.2024		
Test Completed on :	09.01.2024		
Test Report Date :	10.01.2024		
SAMPLE DETAILS FURNISHED BY CUSTOMER			
Source :	Sump Water		
Location :	Sri Chaitanya Techno School, Pallavaram		
Sample drawn by/Date :	Customer / 08.01.2024		
Quantity Received :	250 ml		
Sample container :	Plastic		
Condition of the sample :	Good Condition		
The test result of sample received is as follows.			
Sl. No.	BACTERIOLOGICAL EXAMINATION	Sample No.5833 Result	BIS 10500 - 2012 Max limit
1	Standard plate count CFU/1ml	0	500 Organisms/ml
2	Total coliform CFU/100ml	0	Nil/100 ml
3	Fecal coliform CFU/100ml	0	Nil/100 ml
4	Fecal Streptococcus CFU/100ml	0	Nil/100 ml

Report: 5833-The Water Sample meet the requirement of IS10500:2012 with respect to the parameters tested.

Reviewed by

Authorised Signatory

Principal
Principal
Sri Chaitanya Techno School
No. 110, G.S.T. Road,
Pallavaram, Chennai-600043.

For SREE MURAGAN EDUCATIONAL TRUST
MANAGER
MANAGER

Test Report

Sample Receipt No/Date :	2435/Dt.29.12.2023			
Invoice Details :	2992/Dt.29.12.2023/ Amt Rs.2360/-			
Customer Name and Address :	Sri Chaitanya Techno School, No.110, GST Road, Pallavaram, Chennai-600043			
Test Commenced on :	29.12.2023			
Test Completed on :	30.12.2023			
Test Report Date :	02.01.2024			
SAMPLE DETAILS FURNISHED BY CUSTOMER				
Source :	Sump Water			
Location :	Sri Chaitanya Techno School, Pallavaram			
Sample drawn by/Date :	Customer / 29.12.2023			
Quantity Received :	2 litres			
Sample container :	Plastic			
Condition of the sample :	Good Condition			
Appearance, Colour, Odour :	Clear / Colourless / Agreeable			
The test result of sample received is as follows.				
Sl. No.	I. PHYSICAL EXAMINATION	Method of Testing	Sample No. 5822	IS 10500 : 2012 Permissible limit in the absence of alternate source
1	Turbidity NT Units	APHA 23 rd Edition 2017 - 2130 B	1.1	5
2	Total dissolved Solids mg/L	APHA 23 rd Edition 2017 - 2540 C	42	2000
3	Electrical Conductivity Micro mho/cm	APHA 23 rd Edition 2017 - 2510 B	60	-
II. CHEMICAL EXAMINATION				
4	pH at 25°C	IS 3025 part 11-1983 - Reaffirmed 2017	6.35	6.5-8.5
5	Ph. Alkalinity as CaCO ₃ mg/L	IS 3025-part 23-1983 - Reaffirmed 2014	0	-
6	Total Alkalinity. as CaCO ₃ mg/L	IS 3025-part 23-1986 - Reaffirmed 2014	15	600
7	Total Hardness as CaCO ₃ mg/L	IS 3025 part 21-2009-Reaffirmed 2014	7	600
8	Calcium as Ca mg/L	APHA 23 rd Edition 2017 - 3500 Ca B	1	200
9	Magnesium as Mg mg/L	APHA 23 rd Edition 2017- 3500 Mg B	1	100
10	Sodium as Na mg/L	APHA 23 rd Edition 2017 - 3500 Na B	10	-
11	Potassium as K mg/L	APHA 23 rd Edition 2017 - 3500 K B	0	-
12	Iron as Fe mg/L	APHA 23 rd Edition 2017- 3500 Fe B	0.00	1.0
13	Manganese as Mn mg/L	APHA 23 rd Edition 2017 - 3500 Mn B	0	0.3
14	Free Ammonia as NH ₃ mg/L	APHA 17 th Edition-1989- 4500 NH ₃ C	0.00	0.5
15	Nitrite as NO ₂ mg/L	APHA 23 rd Edition 2017- 4500 -NO ₂ B	0.00	-
16	Nitrate as NO ₃ mg/L	APHA 23 rd Edition 2017- 4500-NO ₃ B	2	45
17	Chloride as Cl mg/L	IS 3025-part 32-1988- Reaffirmed 2014	9	1000
18	Fluoride as F mg/L	APHA 23 rd Edition 2017 - 4500- F-D	0.00	1.5
19	Sulphate as SO ₄ mg/L	IS 3025-part 24-1986-Reaffirmed 2014	0	400
20	Phosphate as PO ₄ mg/L	APHA 23 rd Edition 2017 - 4500 P- D	0.03	-
21	Tidy's Test 4 hrs.as O ₂ mg/L	APHA 23 rd Edition 2017 - 4500 O - B	0.40	-

Reviewed by
K. Rengaraj - Assistant Water Analyst.
Note:

Authorised Signatory
Dr.V. Gopal - Chief Water Analyst.

Priyamai
Principal
Sri Chaitanya Techno School
Sri Chaitanya Techno School
No.110, G.S.T. Road,
Pallavaram, Chennai - 600 043.

For SREE MURAGAN EDUCATIONAL TRUST
MANAGER