



AN ISO 9001 : 2015

keshavramtalabs@gmail.com

TEST REPORT

A.P. Govt Regd No :88/2010

Report no: 1/0097/09/23
Reporting Date: 04/09 /23
Collected On: 31/08/23
Received on: 31/08/23
Sample Particulars: BORE

Issued to
M/s. SRI CHAITANYA TECHNO
SCHOOL REDDYPALEM
GUNTUR.

PHYSICAL PARAMETERS / UNITS

S. No.	PARAMETERS / UNITS	RESULT	IS: 14543:2016 PACKAGED DRINKING WATER DESIRABLE LIMITS	DRINKING WATER SPECIFICATION IS 10500 : 2012 REQUIREMENT (ACCEPTABLE LIMIT	TEST METHOD
1	Color (Hazen Units)	2	2	5	3025 (part 4)
2	Odour (agreeable/not agreeable)	Agreeable	AGREEABLE	AGREEABLE	3025 (part 5)
3	Taste (agreeable/not agreeable)	Disagreeable	AGREEABLE	AGREEABLE	3025 (part 8)
4	Turbidity (NTU)	0.2	2	1	3025 (part 10)
5	pH	7.21	6.0 to 8.5	6.5 to 8.5	3025 (part 11)
6	Electrical Conductivity (micro mhos)	7440	-----	-----	3025 (part 14)
7	Total Dissolved Solids (mg/l)	1560	500	500	3025 (part 15)

CHEMICAL PARAMETERS/UNITS

1	Alkalinity to Phenolphthalein as CaCO ₃ (mg/l)	Nil	-----	-----	3025 (part 23)
2	Alkalinity to Methyl orange as CaCO ₃ (mg/l)	500	200	200	3025 (part 23)
3	Total Hardness as CaCO ₃ (mg/l)	750	-----	200	3025 (part 21)
4	Calcium as Ca [as CaCO ₃] (mg/l)	100 [250]	75	75	3025 (part 40)
5	Magnesium as Mg [as MgCO ₃] (mg/l)	121.5 [500]	30	30	3025 (part 46)
6	Chloride as Cl (mg/l)	439.5	200	250	3025 (part 32)
7	Sulphate as SO ₄ (mg/l)	170	200	200	3025 (part 24)
8	Nitrite as NO ₂ (mg/l)	Nil	0.02	-----	3025 (part 34)
9	Ammonical Nitrogen	Nil	-----	0.5	-----
10	Fluoride as F (mg/l)	0.6	1.0	1.0	Clause 23 of IS 3025
11	Residual free chlorine (mg/l)	Nil	0.2	0.2	3025 (part 26)
12	Iron as (Fe) (mg/l)	0.10	0.1	0.3	3025 (part 53)
13	Silica as (SiO ₂) (mg/l)	22.3	-----	-----	APHA (Part-425 C)

NOTE: Sample is not drawn by KESHAV RAMTA Labs.

Note : The results relate(s) only to the sample tested



JSRao
Lab In-charge