



**Government Of West Bengal  
Office Of The Director General  
West Bengal Fire & Emergency Services  
13D, Mirza Ghalib Street, Kolkata - 16**

Memo no.:IND/WB/FES/20182019/47235

Date: 08-08-2022

**From:**

**Divisional Fire Officer  
Fire Prevention Wing,  
West Bengal Fire & Emergency Services**

**To: GAURAV BHUWALKA**

**2A, NANDA MULLICK LANE, KOLKATA - 700006**

**Sub: Renewal of Fire Safety Certificate for an existing construction of G+V storied, under group educational Building at the premises – 2A, NANDA MULLICK LANE, KOLKATA - 700006**

This is in reference to your application no. 0125191228700486 dated 11-06-2022 regarding the Renewal of Fire Safety Certificate for an existing construction of G+V storied, under group educational Building at the premises – 2A, NANDA MULLICK LANE, KOLKATA - 700006

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

**Recommendation:**

To up-keep the Fire Safety Measures of the aforesaid building the following safety measures need to be incorporated / maintained:

- 1 FCD as shown in the approved plan drawing to be installed within 3 months as per your declaration letter
- 2 Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Driveway.
3. Entrances / Exits as marked in the sanctioned plan drawing must be opened and free from any type of obstruction
4. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.
5. A fire control room including a closed-circuit TV system shall have to be installed which observe all the floors of the

building.

6. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable places of the building.

7. The employees and security staff shall be conversant with installed firefighting equipment's of the building and to operate in the event of fire and testing.

8. Mock fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.

9. A crew of trained Firemen shall be maintained round the clock for fire safety of the building.

10. First Aid firefighting system shall be provided as per I.S. specifications.

11. Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the building to keep them in perfectly good working condition at all the times.

12. Periodical flashing of water in the Hydrants Pipelines shall be made to maintain the efficient working performance of above-mentioned system

13. The Fire Safety audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance register.

14. This Renewal of Fire Safety Certificate is valid for Three Years and has to be renewed from the date of issue of this letter

15. The Renewal Fire Safety Certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services regarding performance of all the Fire Safety arrangements and installations of the building.

Signature valid

Digitally signed by SAROJ  
KUMAR BAGV  
Date: 2022.08.18 20:59:19 IST

Divisional Fire Officer  
West Bengal Fire & Emergency Services