

**GOVERNMENT OF ANDHRA PRADESH
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT.**

From:
D. Malyadri, B.A,
Asst. District Fire Officer,
West Godavari District, Eluru.

To:
The District Educational Officer,
West Godavari District,
Eluru.

Rc.No.614/A1/2011, Dt: 27-04-2016.

Sir,

Sub : A.P. State Disaster Response & Fire Services Department - Eastern Region
West Godavari District - Issuance of Annual Fire Safety Certificate to the
existing Educational Building of Vasavi Ideal Public School, R.S.No.295/2,
Chinatadepalli, Tadepalligudem (M), West Godavari District - Regarding

- Ref :
- 1) Circular Memo. Rc.No.2305/B2/2007, Dt: 02-04-2016 of the Director General, State Disaster Response and Fire Services, A.P., Hyderabad.
 - 2) This Office NOC for Occupancy Rc. No.614/A1/2011 Dt:28-04-2011.
 - 3) Application of the Principal of Vasavi Ideal Public School, R.S.No.295/2, Chinatadepalli, Tadepalligudem (M), West Godavari District.
 - 4) Rc.No.36/SFO/TPG/2016, Dt.27-04-2016 of the Inspection Committee, West Godavari District.

--00--

In the reference 2nd cited, the No Objection Certificate for Occupancy was issued to the existing Non-Multi Storied Educational Building of Vasavi Ideal Public School, R.S.No.295/2, Chinatadepalli, Tadepalligudem (M), West Godavari District and the validity of No Objection Certificate was expired and now the Management has applied for renewal of No Objection Certificate for Occupancy to the above existing educational building vide reference 3rd cited.

2) The Station Fire Officer, Tadepalligudem has inspected the existing Non Multi Storied Educational Building of Vasavi Ideal Public School, R.S.No.295/2, Chinatadepalli, Tadepalligudem (M), West Godavari District on 26-04-2016 and submitted inspection report duly recommended for issue of Annual Fire Safety Certificate to the above Educational building vide reference 4th cited.

- 3) i) Particulars of the Building : RCC roof building
a) Address of the Building : Vasavi Ideal Public School, R.S.No.295/2, Chinatadepalli, Tadepalligudem (M), West Godavari District
b) Area of Plot/Ht. of Bldg : 02 Acres/ 10.00 Mtrs.
c) No. of Blocks / Floors : One / Ground + 2 upper floors.
d) Types of occupancy : Educational Building (B)
e) Total built up area : 6276.00 Sq.Mtrs.

ii) Open Spaces :		
Direction	Required as G.O.Ms.No.168, Dt:07-04-2012	Provided in Mtrs.
East (Front)	03.00 Mtrs.	11.40
West	05.00 Mtrs.	03.05
North	05.00 Mtrs.	08.38
South	05.00 Mtrs.	05.50
		Nil

iii) Floor wise Particulars:-			
Sl. No	Floor	Floor Area in Sq. Mtrs.	Occupancy
1.	Ground	2092.00	Educational
2.	First	2092.00	Educational
3.	Second	2092.00	Educational
Total:		6276.00	280

No. of Students & Staff Members declared by the Management.

(a) Means of Escape :

Sl. No	Details of Staircases	Required	Provided in Mtrs.	Deficit in Mtrs.
1.	Internal Staircase	01.50 Mtrs.	01.50 Mtrs.	Nil
2.	External Staircase	01.25 Mtrs.	01.25 Mtrs.	Nil
Total:		02.75 Mtrs.		

(b)

Highest No. of Students in a floor	Width of staircases required (No. of students divided by 50=...Meters)	Aggregate width of Staircases provided	Deficit
100	100/50 = 02.00 Mtrs.	02.75 Mtrs.	Nil

iv) Fire Safety Measures:

Sl. No	Fire Safety Measures	Required as per Table 23 NBC of India, 2005	Provided	Deficit
1	Fire Extinguishers	62 No's.	62 No's.	Nil
2	Hose reel	06 No's.	06 No's.	Nil
3	Terrace tank	10,000 Ltrs.	10,000 Ltrs.	Nil
4	Booster pump	450 LPM	450 LPM	Nil

4) Hence, it is issued Annual Fire Safety Certificate to the existing Educational Building of Vasavi Ideal Public School, R.S.No.295/2, Chinatadepalli, Tadepalligudem (M), West Godavari District subject to the following conditions.

1.	All the fire protection arrangements shall be maintained in good condition as seen during inspection.
2.	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.
3.	All students / staff members of the institution shall be trained to operate the fire safety equipment during emergency.
4.	Additional / alteration, it any in the building prior permission may be obtained from this department.
5.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.

8) The Management has remitted an amount of Rs.71,695/- (Rupees Seventy one thousand six hundred and ninety five only) vide Ch.No.2055, Dt: 25-04-2016 at ST, Tadepalligudem towards renewal fee and penal interest for five years.

9) The Annual Fire Safety Certificate is valid for a period of one year from the date of issue i.e., up to 26-04-2017.

Yours faithfully,

Asst. District Fire Officer,
West Godavari District,

Eluru.

Copy to the Inspection Committee, West Godavari District.
Copy to the Principal of Vasavi Ideal Public School, R.S.No.295/2, Chinatadepalli, Tadepalligudem (M), West Godavari District.

Md. Shavef
MANAGER

VASAVI IDEAL PUBLIC SCHOOL
CHINATADEPALLI(V), Tadepalligudem
AFFILIATION No-130234

SCHOOL Code - 57081

D. R. S.
PRINCIPAL

VASAVI IDEAL PUBLIC SCHOOL
CHINATADEPALLI(V), Tadepalligudem
AFFILIATION No-130234

SCHOOL Code - 57081