



OFFICE OF THE EXECUTIVE ENGINEER,
RWS&S DIVISION, RAYAGADA.

VILL. AMBAGUDA, PO: J.S.CO. RAYAGADA-765 002.
eerwssrgd@gmail.com, Phone no: 8280408061

Lr. No 3620 / Date 17.07.2023

To,

The Principal
Sri Chaitanya Techno School,
Prajukti Vihar,, Aurobinda Marg,
IACR College Road,
At/Po:Dist. Rayagada 765 002.

Sub: - Regarding issue of safe drinking water Certificate in respect of Sri Chaitanya Techno School, Rayagada.

Ref:- Your letter dated: 11.07.2023


Sir,

With reference to subject cited above, I am to enclose herewith the APPENDIX-VIII for issue of Water Certificate & water test report in respect of Sri Chaitanya Techno School, Rayagada.

This is for your information and necessary action.

Encl:- As above = 1 set

Yours faithfully


Executive Engineer,
RWS&S Division, Rayagada

Memo No. 3621 / Date 17.07.2023

Copy to the Asst. Executive Engineer, RWS&S Sub Division, Rayagada / Junior Engineer No-I, R.W.S& S Section, Rayagada for information and necessary action, with reference to his Lr. No 561. Dt 17.07.2023.


Executive Engineer

File OAV K Singpur






APPENDIX-VIII


PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE

It is certified than an inspection team headed by Sri Manoj Kumar Nayak, Asst. Executive Engineer, RWS&S Sub Division, Rayagada, Name of Department /Office) inspected the Sri Chaitanya Techno School, Rayagada (Name & Address of the School) on Dt 17.07.2023 and found that the: Sri Chaitanya Techno School Rayagada (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/UT Govt.

Signature with Seal: 

Name : Er. Gopal Chandra Nayak

Designation: Executive Engineer,
RWS&S Division, Rayagada.


17/07

To

The Principal
Sri Chaitanya Techno School,
Prajukti Vihar,, Aurobinda Marg,
IACR College Road,
At/Po:Dist. Rayagada 765 002.
(Name & Address of the Institution)

District Level Water Testing Laboratory, RWSS Rayagada



District Level Water Testing Laboratory, RWS&S Division
At-Ambaguda, Po-J.S.Co, Dist- Rayagada. 765002

PAYMENT RECEIPT

SAMPLE ID : DL 903

Candidate Name : THE PRINCIPAL SRI CHAITANYA TECHNO SCHOOL

Contact Number : 7207772350

Sample Received Time : 13.07.2023 : 9.30 am

Amount

Sl. No	Test Name	Amount
1	Temperature	₹ 20.00
2	Colour	₹ 40.00
3	Odour	₹ 20.00
4	Taste	₹ 20.00
5	Turbidity	₹ 60.00
6	pH	₹ 60.00
7	TDS	₹ 60.00
8	Total Alkalinity (as Calcium Carbonate)	₹ 100.00
9	Chloride (as Cl)	₹ 100.00
10	Fluoride (as F)	₹ 120.00
11	Calcium (as Ca)	₹ 100.00
12	Magnesium (As Mg)	₹ 200.00
13	Total Hardness (As CaCO ₃)	₹ 100.00
14	Iron (As Fe)	₹ 100.00
15	E. Coli	₹ 350.00

16	Total Coliform Bacteria	रु 350.00
17	Conductivity	रु 60.00
Total =		रु 1,860.00

Note: This is an auto generated receipt no signature is required

Designed & developed by NIC . Copyright © NJJM 2020

Jal Jeevan Mission

Har Ghar Jal



District Level Water Testing Laboratory, RWSS, Rayagada

District Level Water Testing Laboratory, RWS&S Division, At-Ambaguda, Po-J.S.Co, Dist-Rayagada. 765002 (Test Address Only)

Test Report

Sample ID

DL 903

User Information

Name THE PRINCIPAL SRI CHAITANYA TECHNO SCH Mobile 7207772350
Email: Pin Code 765002
Full Address SRI CHAITANYA TECHNO SCHOOL, PRAJUKTI VIHAR, AUROBINDO MARG, IACR COLLEGE ROAD, RAYAGADA

Sample Description

Source of Sample BORE WELL / TUBE WELL Village BARIJHOLA
Gram Panchayat HALUA Block RAYAGADA
District RAYAGADA State ODISHA
Address BARIJHOLA, RAYAGADA Remarks Raw Water
Latitude Longitude

Date & Time of Sample Collection 13.07.2023 : 08.00 am Date & Time of Sample Received in Lab 13.07.2023 : 9.30 am Date & Time of Sample analysed 14.07.2023 : 4.00 pm Date & Time of report generation 15.07.2023 : 10.00 am

Test Results


Sl. No	Parameter Tested	Unit of Measurement	Requirement (Acceptable Limit) as per BIS 10500	Permissible Limit (in absence of alternate source) as per BIS 10500	Test Result Value	Remarks
1	Calcium (as Ca)	mg/l	75	200	32.020	
2	Chloride as (Cl)	mg/l	250	1000	52.000	
3	Colour	Hazen Units	5	15	0.000	
4	Conductivity	micromhos per centimeter / microsiemens per centimeter	NA	NA	241.540	



Parameter Tested	Unit of Measurement	Requirement (Acceptable Limit) as per BIS 10500	Permissible Limit (in absence of alternate source) as per BIS 10500	Test Result Value	Remarks
5 E.Coli	CFU / 100 ml	Shall not be detectable in any 100 ml sample	No Relaxation	0.000	
6 Fluoride (as F)	mg/l	1	1.5	0.190	
7 Iron (As Fe)	mg/l	1	No Relaxation	0.170	
8 Magnesium (As Mg)	mg/l	30	100	26.240	
9 Odour	NA	Agreeable	Agreeable	Acceptable	
10 pH	NA	6.5-8.5	No Relaxation	6.530	
11 Taste	NA	Agreeable	Agreeable	Acceptable	
12 TDS	mg/l	500	2000	157.000	
13 Temperature	NA	NA	NA	28.700	
14 Total Alkalinity (as Calcium Carbonate)	mg/l	200	600	80.000	
15 Total Coliform	CFU / 100 ml	Shall not be detectable in any 100 ml sample	No Relaxation	0.000	
16 Total Hardness (As CaCO ₃)	mg/l	200	600	120.000	
17 Turbidity	NTU	1	5	0.610	

Note:

- 1)*indicates parameters that are NABL accredited
- 2) This test results relates to the sample tested above.
- 3) The report shall not be reproduced in full without approval of authority
- 4) This is the end of the report


 Authorised Signatory
 Satya Narayana Mahapatro (Test Lab Incharge)

Jal Jeevan Mission aims at potable tap water supply to every home
 Lets join hands to ensure drinking water is potable. It helps in preventing water borne diseases and improved public health

Designed and Developed by NIC. Copyright ©copy NJIM 2023

